



- DIAGRAM NOT TO SCALE
- CONTACT NOLIN RECC LINE DESIGN DEPARTMENT BEFORE STARTING ANY WORK
- CALL 811 BEFORE DIGGING

PAGE 1 OF 2		
 <p>A Touchstone Energy® Cooperative</p> <p>MAIN OFFICE: 270-765-6153</p>	<p>APPROVED BY: NOLIN RECC LINE DESIGN</p>	LAST REVISION
		03/24/2023

## OVERHEAD METER POLE TO UNDERGROUND SERVICE

## NOTES

1. Overhead service locations must be approved by Nolin's Line Design Department prior to service installation.
2. Overhead service will be allowed only under special circumstances.
3. Meter base must have a horn bypass or bypass lever. Do not use a small meter base.
4. Consumer conduit and wire must meet state electrical code requirements.
5. Square pole not acceptable. Pole must be round with minimum 5" top.
6. Pole must be minimum 24'- with 19' above ground and 5' in ground.
7. Meter base and weatherhead must be installed on a side of the meter pole such that it does not interfere with the placement of Nolin's service drop or guy wire.
8. All electric connections, equipment, and equipment grounds shall comply with the National Electrical Code.
9. The member shall furnish and maintain for the life of the electrical service all conduits, conduit straps, grounds, disconnects, meter base, meter pole, and all conductors beyond Nolin's point of delivery.
10. Nolin shall furnish and maintain the meter and overhead service wire from transformer to weatherhead.
11. Energizing of the member's service is contingent upon an approved State or City electrical inspection.

PAGE 2 OF 2			
 A Touchstone Energy® Cooperative MAIN OFFICE: 270-765-6153		OVERHEAD METER POLE TO UNDERGROUND SERVICE	LAST REVISION
	APPROVED BY: NOLIN RECC LINE DESIGN		04/04/2023