



- DIAGRAM NOT TO SCALE
- CONTACT NOLIN RECC LINE DESIGN DEPARTMENT BEFORE STARTING ANY WORK
- CALL 811 BEFORE DIGGING



MAIN OFFICE: 270-765-6153

DRAWN BY:
MATTHEW
VULETA

APPROVED BY:
NOLIN RECC
LINE DESIGN

**OVERHEAD METER POLE
TO UNDERGROUND
SERVICE**

LAST REVISION

12/17/2020

NOTES

1. Overhead service locations must be approved by Nolin's Line Design Department prior to service installation.
2. Overhead service will be allowed only under special circumstances.
3. Meter base must have a by-pass lever. Do not use a small meter base.
4. Consumer conduit and wire must meet state electrical code requirements.
5. Square pole not acceptable. Pole must be round with minimum 5" top.
6. Pole must be minimum 24'- with 19' above ground and 5' in ground.
7. Meter base and weatherhead must be installed on a side of the meter pole such that it does not interfere with the placement of Nolin's service drop or guy wire.
8. All electric connections, equipment, and equipment grounds shall comply with the National Electrical Code.
9. The member shall furnish and maintain for the life of the electrical service all conduits, conduit straps, grounds, disconnects, meter base, meter pole, and all conductors beyond Nolin's point of delivery.
10. Nolin shall furnish and maintain the meter and service drop.
11. Energizing of the member's service is contingent upon an approved State or City electrical inspection.

PAGE 2 OF 2



MAIN OFFICE: 270-765-6153

DRAWN BY:
MATTHEW
VULETA

APPROVED BY:
NOLIN RECC
LINE DESIGN

OVERHEAD METER POLE
TO UNDERGROUND
SERVICE

LAST REVISION

12/17/2020